



CONSUMER TO PROVIDE AND HAVE INSTALLED:

1. WEATHERHEAD
2. CONDUIT
3. WEATHERPROOF CONDUIT TO BOX HUBS
4. 6" LONG CONDUIT NIPPLE
5. THREE WIRE INSULATED SERVICE ENTRANCE CABLES
6. WEATHERPROOF DISCONNECT SWITCH
7. BONDING JUMPER FOR SERVICE EQUIPMENT (#6 CU. MINIMUM)
8. CONNECTOR FOR BONDING JUMPER TO #6 CU. POLE GROUND WIRE
9. 6" x 6" SQUARE OR 5" ROUND AT TOP BY 18 FOOT POST
10. NO. 6 COPPER GROUND WIRE
11. 5/8 INCH X 8 FOOT COPPER CLAD GROUND ROD AND CLAMP
12. 5/8" GALV. EYE BOLT
13. LOCKNUT AND END BUSHINGS

NOTES:

1. IT IS RECOMMEND CONSUMER'S WIRING BE DONE BY A LICENSED ELECTRICIAN, AND ALL OF CONSUMER'S WIRING COMPLY WITH THE NATIONAL ELECTRIC CODE.
2. CO-OP WILL FURNISH THE METER.
3. CONSUMER TO FURNISH AND HAVE THE METER BASE INSTALLED AND THE CONNECTIONS OF THE WIRES INSIDE THE METER BASE.
4. THE ELECTRIC COOPERATIVE WILL NOT CONNECT AND PROVIDE SERVICE IF THE SERVICE ENTRANCE DOES NOT AT LEAST MEET THE REQUIREMENTS OF THIS DRAWING.
5. PHYSICAL LOCATION OF THE POLE WILL BE APPROVED BY THE CO-OP.

OVERHEAD SERVICE  
120/240 VOLT – SINGLE PHASE